

The City of Wildwood

4400 New Jersey Ave

Wildwood, New Jersey 08260

Phone 609-846-2030

Fax 609-522-4965

wcripps@wildwoodnj.org

William J. Cripps

Fire Official

Fire Department

Ernest Troiano III

Chief

Fire Department

COOKING VENDOR GUIDELINES

Cooking vendor permits N.J.A.C. 5:70-2.9(c)1; 1E05/1L12 Type Permit Fee \$54.00

This is an application processing fee and is not refundable.

- **The following are minimum guidelines for each cooking vendor at festivals, carnivals, etc.**
- **A site plan may be required by the Fire Official prior to event.**

FIRE EXTINGUISHER: All cooking vendors shall supply their own fire extinguishers.

N.J.A.C. 5:70-3, 906.2; All fire extinguishers shall comply with NFPA 10/2002. All fire extinguishers shall have a valid dated inspection tag, good of one year.

N.J.A.C. 5:70-3, 904.11.5; Class K portable fire extinguishers are required for cooking with vegetable or animal oils and fats.

N.J.A.C. 5:70-3, 904.11.5.1; Class K portable fire extinguishers are required for cooking with solid fuel.

N.J.A.C. 5:70-3, 904.11.5.2; Class K portable fire extinguishers required for deep fat fryers. (See 2006 IFC-NJ for size and quantity)

PROPANE TANK:

N.J.A.C. 5:70-3, 3003.5.3; Propane tanks shall be secured, to prevent falling over.

N.J.A.C. 5:70-3, 3801.1; Propane tanks and equipment shall comply with NFPA 58/2004.

N.J.A.C. 5:70-3, 3803.2.1; Propane tanks shall not be taken into buildings/tents, (see 2006-1 for exceptions)

Mobile Canteens & Cooking Trailers:

N.J.A.C. 5:70-4.7(g) All cooking operations that produce grease laden vapors shall be equipped with a ventilating hood, duct, and automatic fire suppression system.

N.J.A.C. 5:70-3, 904.6; Dry chemical extinguishing systems shall be maintained and inspected semi-annually as per NFPA 17/2002.

N.J.A.C. 5:70-3, 904.5; Wet chemical extinguishing systems shall be maintained and inspected semi-annually as per NFPA 17A/2002.

N.J.A.C. 5:70-3, 609.2; Excessive grease and residue buildup on kitchen exhaust systems, cleaning required.

MISCELLANEOUS:

N.J.A.C. 5:70-3, 104.3; All appliances shall be listed and labeled and approved by the fire code official. (No homemade appliances).

N.J.A.C. 5:70-3, 2403.8.2; No vehicles shall be parked within 5 feet of tents or canopies.

N.J.A.C. 5:70-3, 2404.15.3; Suitable barricades shall be provided to maintain a distance of 5 feet between the heat producing appliance and the public.

- Propane tanks between 4 and 40 lbs shall have an Overfill Protection Device for filling in NJ.
- Propane tanks shall be hydro tested every 12 years, and not dented or badly rusted.
- Regulator shall be in good condition and the relief valve shall face away from the public areas.

The City of Wildwood

4400 New Jersey Ave

Wildwood, New Jersey 08260

Phone 609-846-2030

Fax 609-522-4965

wcripps@wildwoodnj.org

William J. Cripps
Fire Official
Fire Department

Ernest Troiano III
Chief
Fire Department

- All plastic type protective caps shall be removed from all propane tanks before operating.
- Hoses shall not be frayed or cracked, and there shall not be any type of tape on the hose.
- Hoses shall not be covered with grease and shall not be swollen.
- Hoses shall not create a tripping hazard
- Only approved lighter fluid shall be used for charcoal grills.
- Sterno warmers may be used provided the fuel containers are properly protected from being knocked over and if the fuel containers are properly enclosed within the warmer units.

N.J.A.C. 5:70-2.7(f); The fire official upon inspection may deny or revoke a permit at any time; this can be due to failure to meet the permit conditions, unabated fire code violations or unsafe conditions.