

POTTERS FIELDS PARK MANAGEMENT TRUST



ELECTRICAL SUPPLY

The Park has an electrical supply for events from a pop-up feeder close to the largest lawn (Lawn 3). This has a 16 amp single phase outlet, a 32 amp 3-phase and a 63 amp 3-phase outlet. It is fitted with a 63amp 100ma time delay 3-phase safety device. **NB: Cables and additional components are to be supplied by the event organiser, who must ensure that all equipment plugged into the supply uses a main 3-phase 30ma RCD device to protect all equipment and cabling. It is a condition of use that event risk assessments must acknowledge that it is the event organiser's sole responsibility to provide and install this.** Cable mat must be provided to cover all trailing cables, and DDA-compliant cable ramp used across paths.



